

**Town of Highland, Indiana
 Summary of Sanitary Sewer Overflows and Property Backups
 January 1, 2025 – June 30, 2025**

Event Number and Type	Date and Time Release Began/Ended	Drainage Basin Location	Location of Release	Description of Area Impacted	Reason for SSO	Amount of Flow Released	Rainfall Information and Classification	Name of Receiving Waters Impacted	Did Highland Follow its Overflow Emergency Response Plan?	Actions Taken to Prevent, Minimize or Mitigate Damage, Including Clean-up and Treatment of Affected Area	Actions Taken or Planned to Prevent Recurrence	Did Highland Exceed its Contractual Peak Flow Rate?	Comments
#1 – SSO	04-02-2025 12:40 PM to 04-03-2025 1:05 AM	5 th Street Basin	MH 1230 on 5th St Interceptor (near 8220 5th St)	Reached Receiving Water (At 1 Constructed Overflow out of 5 th St San Sewer into 5 th St Storm Sewer)	Rainfall, Excessive I/I, Under Capacity Sewer	1,456,510 gal	12-hr, 5.7 in. (1.67 inches Rainfall)	Little Calumet River	Yes	Closed valves on LaPorte Street Underground Storage Tank at 12:30 PM on 04/02/2025 to hold back flow from L&J Sanitary Lift Station to minimize volume of overflows. The tank filled to a peak level of 8.20 feet at 9:14 PM on 04/02/2025. The basin valves were opened at 8:00 AM on 04/03/2025 and the basin was empty by 7:25 PM on 04/03/2025.	Highland Sanitary District is implementing its SSO Remedial Action Plan as part of its Consent Decree with IDEM, EPA and DOJ.	No	